



PLANT ITEM No.

24590-PTF-MV-CXP-VSL-00026A

## **MECHANICAL DATA SHEET: VESSEL**

Project:	RPP-WTP	P&ID:	24590-PTF <sub>-</sub> M6-CXP-P0010, 24590-PTF-M6-CXP-P0011, 24590-PTF-M6-CXP-P0013		
Project No:	24590	Process Calculation:	Deleted /1		
Project Site:	Hanford	Vessel Drawing	24590-PTF-MV-CXP-P0008		
Description:	Cesium Ion Exchange Treated LAW Collection Vessel				

R	efe	ren	60	Data	١

Charge Vessels (Tag Numbers)	
Pulsejet Mixers / Agitators (Tag Numbers)	CXP-PJM-00002, CXP-PJM-00003, CXP-PJM-00004, CXP-PJM-00005, CXP-PJM-00006, CXP-PJM-00007
RFDs/Pumps (Tag Numbers)	


**Design Data** 

Quality Level		See Vessel Drawing	Fabrication Specs	24590-WTP-3F	S-MV00-TP001		
Seismic Category		SC-I	Design Code	ASME VIII DIV 1			
Service/Contents		Radioactive Liquid	active Liquid Code Stamp		Yes		
Design Specific Gravity		1.26	NB Registration	Yes			
Maximum Operating Volume	gal	34,370 (Note 3)	Weights (lbs)	Empty	Operating	Test	
Total Volume	gal	39,000 (Note 3)	Estimated	81,400	447,000	407,000	
Environmental Qualification	$\Delta \Gamma$	NIA	Actual * (lbs) 1	75,000	440,000	400,000	

Inside Diameter	inch	180			Wind Design	Not Required		
Length/Height (TL-TL)	inch	nch 294		Snow Design	Not Required			
	E _ = =		Vessel <u>Design</u>	Coil/Jacket <u>Design</u>	Seismic Design	24590-WTP-3PS-MV00-TP002 24590-WTP-3PS-SS90-T0001		
Internal Pressure	psig	Atm	15	NIA	Seismic Base Moment *	ft*lb		
External Pressure	psig	0.12	FV	NIA	Postweld Heat Treat	Not Required		
Temperature	°F	113	138	NIA	Corrosion Allowance	Inch 0.04.		
Min. Design Metal Temp.	°F	40		<u> </u>	Hydrostatic Test Pressure *	psig <b>20</b> /1		

Note: Please note that source, special nuclear and byproduct materials, as defined in the Atomic Energy Act of 1954 (AEA), are regulated at the U.S. Department of Energy (DOE) facilities exclusively by DOE acting pursuant to its AEA authority. DOE asserts, that pursuant to the AEA, it has sole and exclusive responsibility and authority to regulate source, special nuclear, and byproduct materials at DOE-owned nuclear facilities. Information contained herein on radionuclides is provided for process description purposes only.

**ISSUED BY** RPP-WTP PDC



				This Bound Docun	nent <b>Co</b> ntains a	total of 5 sheets.
1	6 205	Issued for Permitting Use	14/	Maldais	Stub	Wolfe
0	5/26/04	Issued for Permitting Use	K. Brightman	R. Simmons	C. Slater	M. Hoffmann
REV	DATE	REASON FOR REVISION	PREPARER	CHECKER	REVIEWER	APPROVER



PLANT ITEM No.

24590-PTF-MV-CXP-VSL-00026A

#### **Materials of Construction**

Component	Material	Minimum Thickness / Size	Ct-i
Top Head	SA-240 316 (Note 2)	See Drawing	Containment
Shell	SA-240 316 (Note 2)	See Drawing	Auxiliary (Note 1)
Bottom Head	SA-240 316 (Note 2)		Primary (Note 1)
Support & Vacuum Ring		See Drawing	Primary (Note 1)
Jacket/Coils/Half-Pipe Jacket	SA-240 304 (Note 2)	See Drawing	NIA
Internals	NIA	NIA	NIA
	SA-240 316 (Note 2)	See Drawing	Thermowells Primary (Note 1)
Pipe	SA-312 TP316 Seamless (Note 2)	See Drawing	Note 1
Forgings/ Bar stock	SA-182 F316 (Note 2)	See Drawing	Note 1
Gaskets	NIA	NIA	NIA
Bolting	NIA	NIA	NIA

### Miscellaneous Data

		missonano suce	
Orientation	Vertical	Support Type	Skirt
Insulation Function	Not Applicable	Insulation Material	Not Applicable
Insulation Thickness (inch)	Not Applicable	Internal Finish	Welds Descaled as Laid
		External Finish	Welds Descaled as Laid

### Remarks

### \* To be determined by the vendor

- Note 1: All welds forming part of the primary and auxiliary containments, including the nozzle attachment welds shall be subjected to 100% volumetric examination.
- Note 2: Maximum carbon content of 0.030% for all welded components.
- Note 3: Vessel volumes are approximate and do not account for manufacturing tolerances, nozzles, and displacement of internals.
- Note 4: This vessel is located in a Black Cell.
- Note 5: Contents of this document are Dangerous Waste Permit affecting.
- Note 6: Deleted./1



PLANT ITEM No. 24590-PTF-MV-CXP-VSL-00026A

**Equipment Cyclic Data Sheet** 

Component Plant Item Number:	24590-PTF-MV-CXP-VSL-00026A
Component Description	Parent Vessel
The information below	is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.
Materials of Construction	SA-240 316
Design Life	40 Years
Component Function and Life Cycle Description	This vessel receives and stores waste in a batch transfer. It shall be designed to be filled to the maximum content level over a period of 22 hours and emptied in 10 hours to complete a 32 hour cycle. Additionally, this vessel will be subjected to fluid dynamic forces from the operation of the pulse jet mixers during the process of suspending the solids. This vessel is washed down not more than once per year.

Load Type		Min	Max	Number of Cycles	Comment
Design Pressure	psig	FV	15	10	Nominal assumption for testing
Operating Pressure	psig	-0.12	0	NIA	This vessel will remain under constant pressure depending upon the vessel vent system
Operating Temperature	°F	59	113	NIA	Temperature will not cycle appreciably with vessel cycling
Contents Specific Gra	vity	1.00	1.26	NIA	Normally 1.2 without cycling
Contents Level	inch	43	309	3690	Liquid level from crown of bottom head
Localized Featur	es				
Supports				Same as content	ts level

### Notes

Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty unless otherwise noted.




PLANT ITEM No. 24590-PTF-MV-CXP-VSL-00026A

Hydrodynamic Loading /


In normal operation, pulse jet mixers discharge liquid into the parent vessel imposing a cyclical hydrodynamic load on all internal components. Occasionally, an upset condition designated 'overblow' causes air to be discharged from any single pulse jet mixer. All internal components shall be designed for the combination of the normal operational hydrodynamic loads and overblow loads, and this load combination is also to be assumed to act concurrently with seismic loads.

The following table indicates the normal hydrodynamic pressure for ranges of elevations in the vessel and the number of design cycles for each condition. The hydrodynamic forces cycle between the indicated pressure ranges applied across the projected area of the component. Positive hydrodynamic forces act in the radial, outward direction and the vertical, upward direction. Seller shall apply the radial load simultaneously in the radial direction and normal to the radial direction in the horizontal plane.



Normal Operation Hydrodynamic Pressure Range, psi							Number of	
Elevation A Elevation B		Elevation C		Elevation D		Cycles		
Radial	Vertical	Radial	Vertical	Radial	Vertical	Radial	Vertical	, , , , , ,
-0.09 to 0.29	-0.74 to 0.48	-0.02 to 0.22	-0.01 to 0.40	-0.05 to 0.12	-0.01 to 0.40	-0.03 to 0.10	-0.01 to 0.40	21.5 X 10 <sup>5</sup>

Overblow loads vary as a function of the distance from the center of the overblowing pulse jet mixer nozzle and the elevation 'H' above the overblowing pulse jet mixer nozzle up to the overflow level as plotted:



The overblow pressure shall only be applied to the projected area of the overblowing pulse jet mixer in the vertical, upward direction and to all surrounding components in the horizontal plane, radiating from the overblowing pulse jet mixer. Seller shall consider that any single pulse jet mixer may overblow 100 cycles.

#### **Notes**

 Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty unless otherwise noted.



PLANT ITEM No. 24590-PTF-MV-CXP-VSL-00026A

**Equipment Cyclic Data Sheet** 

Component Plant Item Number:	24590-PTF-MV-CXP-PJM-00002, 24590-PTF-MV-CXP-PJM-00003, 24590-PTF-MV-CXP-PJM-00004, 24590-PTF-MV-CXP-PJM-00005, 24590-PTF-MV-CXP-PJM-00006, 24590-PTF-MV-CXP-PJM-00007
Component Description	Pulse Jet Mixers

i ne imormation below	is provisional and envelopes operational duty for fatigue assessment. It is not to be used as operational data.
Materials of Construction	SA-240 316
Design Life	40 Years
Component Function and Life Cycle Description	These pulse jet mixers (PJMs) are cyclically loaded using vacuum to fully fill the PJM with process liquid and compressed air to fully empty the PJM. The PJMs are contained within a parent vessel with varying liquid level. They shall be designed to cycle between the maximum design pressure and the minimum design pressure plus the external static head imposed by the parent vessel. The PJM supports shall be designed to cycle between fully buoyant (PJM empty and parent vessel full) and fully loaded (PJM full and parent vessel empty) states. Thrust load shall be applied only to the fully buoyant state. Assume the parent vessel is full for 50% of the number of PJM cycles.

Contents Specific Gravity  1.00  1.26  NiA  Normally 1.2 without cycling  Contents Level inch Empty Flooded 2.15 x 10 <sup>7</sup> Thrust 1 lbf 0 314  2.15 x 10 <sup>7</sup> Localized Features  Nozzles	Load Type		Min	Max	Number of Cycles	Comment
Operating Temperature  **F 59 113 N/A Temperature will not cycle appreciably with very cycling.  Contents Specific Gravity 1.00 1.26 N/A Normally 1.2 without cycling  Contents Level inch Empty Flooded 2.15 x 107  Thrust 1 Ibf 0 314 2.15 x 107  Localized Features  Nozzles	Design Pressure	psig	FV	80	10	Nominal assumption for testing
Temperature  Contents Specific Gravity  1.00  1.26  NiA  Normally 1.2 without cycling  Contents Level inch Empty Flooded 2.15 x 10 <sup>7</sup> Thrust 1 lbf 0 314  2.15 x 10 <sup>7</sup> Localized Features  Nozzles	Operating Pressure	psig	FV	72.5	2.15 x 10 <sup>7</sup>	
Contents Level inch Empty Flooded 2.15 x 10 <sup>7</sup> Thrust 1 lbf 0 314 2.15 x 10 <sup>7</sup> Localized Features  Nozzles	•	°F	59	113	NIA	Temperature will not cycle appreciably with vessel cycling.
Thrust 1 lbf 0 314 2.15 x 10 <sup>7</sup> Localized Features  Nozzles	Contents Specific Gravity		1.00	1.26	NIA	<del> </del>
Localized Features  Nozzles	Contents Level	inch	Empty	Flooded	2.15 x 10 <sup>7</sup>	
Nozzies	Thrust 1	lbf	0	314	2.15 x 10 <sup>7</sup>	
Consorts	Localized Featur	es		·	<u> </u>	
Supports BuoyantiLoaded Same as contents level	Nozzles					
	Supports		BuoyantiLoaded		Same as contents level	

### Notes

Cycle increase: The Seller must increase the numbers of operational cycles given above by 10% to account for commissioning duty unless otherwise noted.